

**RECENTLY IDENTIFIED CORRECTIONS**  
(November 3, 2004)

**PART 9 - CALIFORNIA FIRE CODE**

Pg. 1-216 – Table 8001.14—A: Table 8001.14—A was published in error. The correct table should read as follows:

CONDITION		Retail and Wholesale Display and Storage Exempt Amount per Control Area	
MATERIAL	CLASS	Solids (pounds)	Liquids Gallons (pounds)
		X 0.4536 for kg	X 3.785 for L X 0.4536 for kg
1. Health Hazard Materials - Non-Flammable and Non-Combustible Solids, Liquids, and Gases			
Carcinogens		N.L.	N.L.
Corrosives <sup>2,3</sup>		10,000	1,000
Highly Toxics		20 <sup>2,3</sup>	2 <sup>2,3</sup>
Irritants		N.L.	N.L.
Other Health Hazards		N.L.	N.L.
Sensitizers		N.L.	N.L.
Toxics <sup>2,3</sup>		1,000	100
2. Physical Hazard Materials - Non-Flammable and Non-Combustible Solids and Liquids			
Oxidizers <sup>2,3</sup>	4	N.A.	N.A.
	3	1,150	115
	2	2,250	225
	1	18,000	1,800
Unstable (Reactives) <sup>2,3</sup>	4	N.A.	N.A.
	3	550	55
	2	1,150	115
	1	N.L.	N.L.
Water (Reactives)	3 <sup>2,3</sup>	550	55
	2 <sup>2,3</sup>	1,150	115
	1	N.L.	N.L.

N.A. = Not Allowed

N.L. = Not Limited

<sup>1</sup> Hazard categories are as specified in Section 8002.

<sup>2</sup> Exempt amounts may be increased 100 percent in sprinklered buildings. When Footnote 3 applies, the increase for both footnotes can be applied.

<sup>3</sup> Exempt amount may be increased 100 percent in approved storage cabinets. See Section 8001.10.6 for approved cabinets. When Footnote 2 also applies, the increase for both footnotes can be applied.